



**LEGEND: PUBLIC LIGHTING**

- Luminaire A P852K-24-R2A-740-HE-0300-15W  
6m Column Qty 93
- Luminaire A P852K-24-R2A-740-HE-0300-15W  
6m Column Qty 1 (0.3m Twin arm bracket, 2 luminaires)
- Luminaire B P852K-24-R3A-740-HE-0200-10W  
6m Raise & Lower Column Qty 43.
- Luminaire B P852K-24-R3A-740-HE-0200-10W  
6m Raise & Lower Column Qty 4.
- Luminaire C P852K-24-F2A-740-HE-0300-15W  
6m Column Qty 4.

Luminaire D P852K-24-R3A-740-HE-0450-21W  
6m Raise & Lower Column Qty 14.

**Notes:**  
All luminaires must have Constant Light Output (CLO).  
Automatically dimmed to 75% each night from 12 midnight to 6am. (U14 Profile)  
All luminaires to have 7pin NEMA sockets fitted.  
Electrical power to be supplied via 35mm cable.  
All columns, luminaires, cables and fittings, shall comply with Local Authority General Specification for Public Lighting.  
No trees to be located within falling distance of P/L columns.  
Minimum set-back of columns is 800mm from face of kerb.

**NOTE**

ALL DIMENSIONS TO BE CHECKED ON SITE  
NO DIMENSIONS ON THIS DRAWING  
NO DRAWING IS TO BE READ IN CONJUNCTION WITH  
RELEVANT CONSULTANTS DRAWINGS  
NO PART OF THIS DOCUMENT MAY BE REPRODUCED OR  
TRANSMITTED IN WHOLE OR IN PART, IN ANY FORM OR BY ANY  
SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION  
OF THE LANDSCAPE ARCHITECT AS COPYRIGHT HOLDER  
AS AGREED FOR USE ON THE PROJECT FOR WHICH THE  
DOCUMENT WAS ORIGINALLY ISSUED.  
FOR DRAWING INDEX, GENERAL NOTES, REFER TO  
DWG L1-001

**REVISIONS**

**JOB DESCRIPTION**

Site	WOODTOWN, BALLYCULLEN
Project	BALLYCULLEN LRD
Title	GENERAL ARRANGEMENT PLAN



**NMP**  
Niall Montgomery + Partners

Architects : 33 Rock Road, Williamstown, Blackrock, Co. Dublin  
Telephones : 2121 800 Fax : 2121 007 E mail : info@nmp.ie