

NOTE:
PUBLIC FOUL PIPE MATERIAL TO BE U-PVC (STIFFNESS CLASS 8) AND IN COMPLIANCE WITH SECTION 3.13 OF IRISH WATER CODE OF PRACTICE.

NOTE:
FOUL SEWERS TO BE CONSTRUCTED WITH CONCRETE SURROUND IN ACCORDANCE WITH IRISH WATER STD-WW-08 WHERE VERTICAL CLEARANCE FROM SURFACE WATER IS LESS THAN 300mm AND WHERE DEPTH OF COVER TO ROAD IS LESS THAN 1.2m

NOTE:
FOUL INSPECTION CHAMBERS FOR EACH HOUSE UNIT TO COMPLY WITH IRISH WATER STANDARD DETAILS STD-WW-02 AND STD-WW-03

NOTE:
WHERE FOUL MANHOLES ARE LOCATED IN LANDSCAPED/GRASS AREAS TO ENSURE THAT MANHOLE COVERS ARE IDENTIFIABLE AND ACCESSIBLE MANHOLE COVERS ARE TO BE SURROUNDED WITH A CONCRETE PLINT, 200mm ALL ROUND 100mm DEEP FORMED WITH C20/25 CONCRETE

This drawing should not be scaled. Dimensions to be verified on site.
Any discrepancies should be referred to the Engineer prior to work being put in hand.
This drawing is the property of Waterman Moylan Consulting Engineers Limited and is issued on the condition that it is not copied, reproduced, retained or disclosed to any unauthorized person, either wholly or in part without the consent in writing of Waterman Moylan Consulting Engineers Limited.
Block S East Point Business Park, Dublin D03 H3F4 Ireland
T+353 1 664 8900

NOTES:

1. DO NOT SCALE. USE FIGURED DIMENSIONS ONLY.
2. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL AND ENGINEERING DRAWINGS.

