



NOTE

ALL DIMENSIONS TO BE CHECKED ON SITE

NO DIMENSIONS TO BE SCALED FROM THIS DRAWING

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH RELEVANT CONSULTANTS DRAWINGS

NO PART OF THIS DOCUMENT MAY BE RE-PRODUCED OR TRANSMITTED IN ANY FORM OR STORED IN ANY RETRIEVAL SYSTEM OF ANY NATURE WITHOUT THE WRITTEN PERMISSION OF THE LANDSCAPE ARCHITECT AS COPYRIGHT HOLDER EXCEPT AS AGREED FOR USE ON THE PROJECT FOR WHICH THE DOCUMENT WAS ORIGINALLY ISSUED

SHOP DRAWINGS TO BE SUBMITTED, WHERE REQUIRED AND REQUESTED, FOR APPROVAL






CLIENT:



ARCHITECTS:



LEGEND: PUBLIC LIGHTING

-  Luminaire A P852K-2A-R2A-740-HE-0300-15W  
6m Column Qty 93
-  Luminaire A P852K-2A-R2A-740-HE-0300-15W  
Luminaire B P852K-2A-R3A-740-HE-0200-10W  
6m Column Qty 1 (0.3m Twin arm bracket, 2 luminaires)
-  Luminaire B P852K-2A-R3A-740-HE-0200-10W  
6m Raise & Lower Column Qty 43.
-  Luminaire C P852K-2A-F2A-740-HE-0300-15W  
6m Column Qty 4.
-  Luminaire D P852K-2A-R3A-740-HE-0450-21W  
6m Raise & Lower Column Qty 14.

1.0 LUX  
3.0 LUX  
5.0 LUX

Notes:  
All LED lanterns must have Constant Light Output (CLO).  
Automatically dimmed to 75% each night from 12 midnight to 6am. (U14 Profile)  
All lanterns to have 7pin NEMA sockets fitted.


Electronic Photocells switched at 35/18lux  
All columns, luminaires, cable and pillars, shall comply with Local  
Authority General Specification for Public Lighting.

No trees to be located within falling distance of P/L columns.  
Minimum set-back of columns is 800mm from face of kerb.

REFERENCE: THIS DRAWING IS NOT FOR CONSTRUCTION

[illegible]

Job No.	--	Drawn By	BMA, JD, RK
Dwg No.	L-103	Checked By	JM
Scale	1 : 1000 @A1	Date	2025
JOB DESCRIPTION			
Site	Woodtown, Ballycullen, Dublin 16.		
Project	BALLYCULLEN LRD		
Title	PUBLIC LIGHTING		



# NMP

Niall Montgomery + Partners